

Classification Report

Number	19-002698-PR02 (NW-A01-03-en-01)
Owner	AUMÜLLER Aumatic GmbH Gemeindewald 11 86672 Thierhaupten Germany
Product	Bottom-hung window, motor-operated
Designation	System: AUMÜLLER ferralux NRWG 100
Details	Material Aluminium system with thermal break; Type of opening Tilt; Opening direction Inwards; Overall dimensions (W x H) 3190 mm x 2190 mm Drive: chaindrive 2 x KS4 600 S12 24 V DC with locking drive FVUB R S3 M-COM (513930)
Special features	

Result

Mechanical durability according to EN 12400:2002-10



Class: 3

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 19-002698-PR02 PB-A01-03-de-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

19.11.2020



Thomas Krichbaumer
Deputy Head of Testing Department
Building Component Testing



Peter Marquardt, Dipl.-Ing. (FH)
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 7EA-D4300